



## OFFICIAL LISTING

NSF certifies that the products appearing on this Listing conform to the requirements of NSF/ANSI/CAN 60 - Drinking Water Treatment Chemicals - Health Effects

This is the Official Listing recorded on October 24, 2023.

**Wex Technologies Pvt. Ltd.**  
**Survey No. 244./2, Rajiv Gandhi**  
**Infotech Park, Phase-1, Hinjawadi**  
**Pune 411057, Landmark: Near Sai**  
**Service Station**  
**India**  
**91 206 6547000**

**Facility: Maharashtra, India**

<b>Chemical/ Trade Designation</b>	<b>Function</b>	<b>Max Use</b>	
<b>Aminotrimethylene Phosphonic Acid</b>			
GENESYS HR	Reverse Osmosis Antiscalant	5	mg/L
Genesys MP	Reverse Osmosis Antiscalant	10	mg/L
<b>Miscellaneous Corrosion Chemicals</b>			
Genetech CP	Corrosion Control	25	mg/L
<b>Miscellaneous Treatment Chemical</b>			
CHEMSOL 27	Distillation Antiscalant	10	mg/L
Genesys CAS	Reverse Osmosis Antiscalant	10	mg/L
Genesys LF	Reverse Osmosis Antiscalant	10	mg/L
Genesys LF 60	Reverse Osmosis Antiscalant	10	mg/L
Genesys LS	Reverse Osmosis Antiscalant	10	mg/L
Genesys SI	Reverse Osmosis Antiscalant	10	mg/L
WexTreat 27	Distillation Antiscalant	10	mg/L
<b>Miscellaneous Water Supply Products</b>			
CHEMSOL 63 [1]	Antifoamer	.25	mg/L
Genesol 38 [2] [3]	Membrane Cleaner	NA	
Genesol 40 [2] [3]	Membrane Cleaner	NA	
Genesol 703 [2] [3]	Membrane Cleaner	NA	
Genesol 704 [2] [3]	Membrane Cleaner	NA	
Genesol 721 [2] [3]	Membrane Cleaner	NA	
Genesol 80 [2]	Membrane Cleaner	NA	
Genesol UF Fe [2]	Membrane Cleaner	NA	
WexTreat AF 63 [1]	Antifoamer	.25	mg/L
<b>Sodium Chlorite [CL]</b>			
Chemsol 7214	Chlorine Dioxide Production	22	mg/L

[1] Certified for addition to the feedwater for evaporative desalination units only.

[2] This product is designed to be used off-line and flushed out prior to using the system for drinking water, following manufacturer's use instructions.

[3] The pH of the influent and effluent water should be monitored to ensure that all traces of the product have been removed before placing into service.

Note: Additions shall not be made to this document without prior evaluation and acceptance by NSF.



[CL] The residual levels of chlorine (hypochlorite ion and hypochlorous acid), chlorine dioxide, chlorate ion, chloramine and disinfection by-products shall be monitored in the finished drinking water to ensure compliance to all applicable regulations.

Note: Additions shall not be made to this document without prior evaluation and acceptance by NSF.

2 of 2



## OFFICIAL LISTING

NSF certifies that the products appearing on this Listing conform to the requirements of the NSF Nonfood Compounds Registration Program

This is the Official Listing recorded on January 9, 2024.

**Wex Technologies Pvt Ltd**  
**1st Fl., ASAPL, Surv. 244/2, RGIP**  
**Ph. 1, Hinjewad, Pimpri, Chinchwad**  
**Pune, Maharashtra 411057**  
**India**  
**91 206 6547000**

Product Designation	Registration Number	Category Code
Chemsol 2702	167912	G3
CHEMSOL 2703	168677	G3
Chemsol 9221	167911	G6
WexTreat 9221	168612	G6

G3 Silicate water treatment compounds.

G6 Boiler treatment products.

Note: Additions shall not be made to this document without prior evaluation and acceptance by NSF.

1 of 1